

DREXAN™ HeatTracer

Components

VisualGuide - Metallic Components

Drexan™ HeatTracer Metallic Components are for installation with PipeGuard and RoofGuard heating cables. HeatTracer components may be installed in temperatures as low as - 40 degrees. Junction boxes are cast Aluminum with Neoprene o-rings to meet NEMA 4 requirements. Housings have 3/4" NPT threaded hubs to ensure grounding continuity.

High Profile

HP-PC-1 AL

Power Connection – Single Cable



HP-LE-1R/ HP-LE-2R

Lighted End Seal 120v/240v



HP-LEA-1R/HP-LEA-2R

Adapter Kits - Light Enclosure Only
(for use with LP-E AL Kit)

Drexan™ and National Electrical Codes both require ground-fault protection of equipment and a grounded metallic covering on all heating cables. Ground-fault protection of components and each heating cable branch circuit reduces the danger of fire caused by continuous electrical arcing resulting from improper installation or damage to the heating cable. Following are some of the ground-fault breakers that satisfy this equipment protection requirement: Square D Type QOB-EPD or QO-EPD and Cutler Hammer (Westinghouse) Type QBGFEF

Approvals: Class I, Div. 2, Groups A, B, C, D / Class II, Div. 2, Groups E, F, G / Class III
NOTE: Adapter kits available for Class I, Div. 1



Right Product, Right Place, Right Price.™